

GONIOPHOTOMETERS SYSTEM TEST REPORT


LUMINAIRE PHOTOMETRIC TEST REPORT

Report number: 2018010812


MANUFACTURER: SGSLight Limited	Address:	
NAME: TLP-30120-36-NW-100E	TYPE:LED Panel Light	WEIGHT:
SPECIFICATION:4000K CRI>80	DIMENSION: 296x1196mm	SERIAL No.:2018010812

DATA OF LAMP		Imax(cd)	1303	S/MH(C0/180)	1.29
MODEL	4000K	EFFICIENCY(%)	100.0	S/MH(C90/270)	1.27
NOMINAL POWER(W)	36	TOTAL FLUX(lm)	3844.8	Voltage(V)	219.5
RATED VOLTAGE(V)	220	EFFICIENCY(lm/W)	105.6	Current(A)	0.172
NOMINAL FLUX(lm)	3844.9	η up(%)	1.2	Power(W)	36.40
LAMPS QUANTITY	1	η down(%)	98.8	Power Factor(PF)	0.961
TEST VOLTAGE(V)	219.5	Effictive Flux(lm)	3742.6	EEI	0.132

LUMINOUS INTENSITY DISTRIBUTION



LUMINOUS INTENSITY DISTRIBUTION



Test System:HOPOO HPG1900
 Temperature:25.3DEG
 Operators:Jason
 Test Date:2018-01-08


Test Set: 7.0deg/s B-Beta (TYPE B)
 Humidity:65.0%
 Test Distance:7.000 m
 Remarks:

GONIOPHOTOMETERS SYSTEM TEST REPORT

AVERAGE AND CENTER E Figure

Report number: 2018010812

MANUFACTURER: SGSLight Limited	Address:	
NAME: TLP-30120-36-NW-100E	TYPE:LED Panel Light	WEIGHT:
SPECIFICATION:4000K CRI>80	DIMENSION: 296x1196mm	SERIAL No.:2018010812



Angle:114.2deg

Test System:HOPOO HPG1900
 Temperature:25.3DEG
 Operators:Jason
 Test Date:2018-01-08

Test Set: 7.0deg/s B-Beta (TYPE B)
 Humidity:65.0%
 Test Distance:7.000 m
 Remarks:

GONIOPHOTOMETERS SYSTEM TEST REPORT

ZONAL FLUX DIAGRAM

Report number: 2018010812

MANUFACTURER: SGSLight Limited		Address:	
NAME: TLP-30120-36-NW-100E		TYPE:LED Panel Light	WEIGHT:
SPECIFICATION:4000K CRI>80		DIMENSION: 296x1196mm	SERIAL No.:2018010812

γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	zone	total
5.0	1301	1295	1292	1289	1291	1287	1290	1294	0- 5	30.98	30.98
10.0	1290	1283	1282	1269	1269	1266	1278	1281	5- 10	91.85	122.8
15.0	1266	1262	1249	1242	1238	1237	1245	1260	10- 15	149.7	272.5
20.0	1232	1223	1216	1198	1193	1192	1211	1221	15- 20	202.5	475.1
25.0	1188	1179	1164	1147	1141	1142	1160	1176	20- 25	248.7	723.8
30.0	1142	1123	1113	1088	1077	1082	1109	1122	25- 30	286.8	1011
35.0	1071	1059	1040	1019	1006	1012	1038	1059	30- 35	315.6	1326
40.0	996.6	987.4	967.1	944.3	928.8	936.9	967.0	988.9	35- 40	333.5	1660
45.0	915.0	897.4	878.4	857.2	843.0	851.0	879.2	900.9	40- 45	340.6	2001
50.0	822.8	807.6	789.7	770.2	746.9	764.7	791.3	813.0	45- 50	336.2	2337
55.0	727.9	706.7	686.7	669.4	649.1	662.8	691.9	714.1	50- 55	320.5	2657
60.0	623.5	604.8	583.7	567.6	543.5	559.9	592.5	614.4	55- 60	294.3	2952
65.0	517.4	490.0	475.0	464.0	439.0	459.2	485.7	502.9	60- 65	258.7	3210
70.0	408.4	379.1	366.2	360.8	332.2	357.5	378.9	394.7	65- 70	215.5	3426
75.0	303.0	271.5	261.6	256.9	231.1	253.4	277.1	289.3	70- 75	167.1	3593
80.0	201.5	166.6	156.9	162.1	133.1	162.2	175.3	186.5	75- 80	116.4	3710
85.0	104.0	75.87	80.26	77.44	46.69	79.19	91.26	91.98	80- 85	66.61	3776
90.0	18.76	3.479	3.528	3.626	6.272	3.969	7.203	7.399	85- 90	22.46	3799
95.0	1.862	4.206	4.091	4.075	10.14	4.248	5.904	5.293	90- 95	2.535	3801
100.0	2.303	4.704	4.655	4.711	9.848	4.694	4.606	4.508	95-100	2.549	3804
105.0	3.087	5.083	5.243	5.474	9.897	5.305	5.096	4.721	100-105	2.710	3806
110.0	4.263	5.467	5.831	6.200	9.163	5.911	5.586	4.894	105-110	2.915	3809
115.0	5.095	5.900	6.419	6.956	9.261	6.621	6.076	5.229	110-115	3.081	3812
120.0	5.536	6.381	7.006	7.655	9.750	7.417	6.566	5.495	115-120	3.223	3816
125.0	6.370	6.871	7.594	8.370	9.603	8.152	7.056	5.819	120-125	3.315	3819
130.0	7.938	7.527	8.182	9.099	10.53	8.874	7.546	6.257	125-130	3.362	3822
135.0	8.428	7.894	8.770	9.719	11.02	9.281	8.036	6.870	130-135	3.370	3826
140.0	9.211	8.705	9.358	10.25	11.85	10.01	8.526	7.358	135-140	3.312	3829
145.0	10.04	9.357	9.946	10.83	13.03	10.55	9.016	7.910	140-145	3.192	3832
150.0	10.48	9.835	10.53	11.35	13.08	11.10	9.506	8.238	145-150	2.990	3835
155.0	11.66	10.70	11.12	12.12	13.52	11.51	9.996	8.793	150-155	2.707	3838
160.0	12.10	11.40	11.71	12.31	13.91	11.94	10.48	9.697	155-160	2.349	3840
165.0	12.88	12.12	12.29	12.90	13.57	12.36	10.97	10.03	160-165	1.930	3842
170.0	13.27	12.85	12.88	13.24	13.57	12.77	11.46	10.67	165-170	1.445	3844
175.0	13.32	13.44	13.47	13.64	13.57	12.47	11.95	11.34	170-175	0.903	3845
180.0	14.06	14.06	14.06	14.06	12.44	12.44	12.44	12.44	175-180	0.309	3845
DEG	LUMINOUS INTENSITY:cd									UNIT:lm	

Test System:HOPOO HPG1900
 Temperature:25.3DEG
 Operators:Jason
 Test Date:2018-01-08


Test Set: 7.0deg/s B-Beta (TYPE B)
 Humidity:65.0%
 Test Distance:7.000 m
 Remarks:

GONIOPHOTOMETERS SYSTEM TEST REPORT

ISOCANDELA DIAGRAM

Report number: 2018010812

MANUFACTURER: SGSLight Limited	Address:	
NAME: TLP-30120-36-NW-100E	TYPE:LED Panel Light	WEIGHT:
SPECIFICATION:4000K CRI>80	DIMENSION: 296x1196mm	SERIAL No.:2018010812



Test System:HOPOO HPG1900
 Temperature:25.3DEG
 Operators:Jason
 Test Date:2018-01-08


Test Set: 7.0deg/s B-Beta (TYPE B)
 Humidity:65.0%
 Test Distance:7.000 m
 Remarks:

GONIOPHOTOMETERS SYSTEM TEST REPORT

ISOLUX DIAGRAM

Report number: 2018010812

MANUFACTURER: SGSLight Limited	Address:	
NAME: TLP-30120-36-NW-100E	TYPE:LED Panel Light	WEIGHT:
SPECIFICATION:4000K CRI>80	DIMENSION: 296x1196mm	SERIAL No.:2018010812



Test System:HOPOO HPG1900
 Temperature:25.3DEG
 Operators:Jason
 Test Date:2018-01-08

Test Set: 7.0deg/s B-Beta (TYPE B)
 Humidity:65.0%
 Test Distance:7.000 m
 Remarks:

GONIOPHOTOMETERS SYSTEM TEST REPORT

Uncorrected UGR Table

Report number: 2018010812

MANUFACTURER: SGSLight Limited					Address:					
NAME: TLP-30120-36-NW-100E					TYPE:LED Panel Light			WEIGHT:		
SPECIFICATION:4000K CRI>80					DIMENSION: 296x1196mm			SERIAL No.:2018010812		
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	17.3	18.8	17.6	19.1	19.3	17.1	18.6	17.3	18.8	19.0
3H	19.0	20.4	19.3	20.6	20.9	18.6	20.0	18.9	20.2	20.5
4H	19.7	21.0	20.0	21.3	21.6	19.2	20.5	19.5	20.8	21.1
6H	20.3	21.5	20.6	21.8	22.1	19.6	20.9	20.0	21.2	21.5
8H	20.5	21.7	20.8	22.0	22.3	19.8	21.0	20.2	21.3	21.6
12H	20.6	21.8	21.0	22.1	22.5	19.9	21.1	20.3	21.4	21.7
4H 2H	17.9	19.2	18.2	19.5	19.8	17.7	19.0	18.0	19.3	19.6
3H	19.7	20.9	20.1	21.2	21.6	19.4	20.6	19.8	20.9	21.2
4H	20.6	21.6	21.0	22.0	22.3	20.2	21.2	20.6	21.6	21.9
6H	21.3	22.2	21.7	22.6	23.0	20.7	21.7	21.1	22.1	22.4
8H	21.5	22.4	22.0	22.8	23.2	20.9	21.8	21.4	22.2	22.6
12H	21.7	22.6	22.2	23.0	23.4	21.1	21.9	21.6	22.3	22.8
8H 4H	20.8	21.7	21.2	22.1	22.5	20.5	21.3	20.9	21.7	22.1
6H	21.7	22.4	22.1	22.8	23.3	21.2	21.9	21.6	22.3	22.8
8H	22.0	22.7	22.5	23.1	23.6	21.5	22.1	22.0	22.6	23.1
12H	22.3	22.9	22.8	23.3	23.8	21.8	22.3	22.2	22.8	23.3
12H 4H	20.8	21.6	21.3	22.0	22.5	20.5	21.3	20.9	21.7	22.1
6H	21.7	22.4	22.2	22.8	23.3	21.2	21.9	21.7	22.4	22.8
8H	22.1	22.7	22.6	23.1	23.6	21.6	22.2	22.1	22.6	23.1
Variations with the observer position at spacings:										
S = 1.0H	+ 0.1 / - 0.2					+ 0.2 / - 0.2				
1.5H	+ 0.2 / - 0.3					+ 0.2 / - 0.3				
2.0H	+ 0.1 / - 0.3					+ 0.2 / - 0.3				

CIE Pub.117 Corrected 3845 lm Total Lamp Luminous Flux. (8log(F/F0) = 4.7)

Test System:HOPOO HPG1900
 Temperature:25.3DEG
 Operators:Jason
 Test Date:2018-01-08

Test Set: 7.0deg/s B-Beta (TYPE B)
 Humidity:65.0%
 Test Distance:7.000 m
 Remarks: